

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 2</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0001</div>		3. EFFECTIVE DATE <div style="text-align: center;">15-Jun-2007</div>		4. REQUISITION/PURCHASE REQ. NO. SEE SCHEDULE		5. PROJECT NO.(If applicable) <div style="text-align: center;">F1-00215-6J</div>	
6. ISSUED BY <div style="text-align: center;">CODE</div> ACA FORT RILEY DIRECTORATE OF CONTRACTING 7410 APENNINES DR FORT RILEY KS 66442		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center;">CODE</div>		See Item 6			
W911RX							
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X 9A. AMENDMENT OF SOLICITATION NO. W911RX-07-B-0005			
				X 9B. DATED (SEE ITEM 11) 06-Jun-2007			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Solicitation: Retrofit Lighting. Purpose of the amendment to provide answers and revise TE-1 Bldg 7940 Drawing.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 15-Jun-2007	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGESResponses to Bidder Questions 15 Jun 07
W911RX-07-B-0005

1. On the breaker panel light fixture, if we install a CFL as shown can you advise what wattage of fixture you would like to have installed?

Response: Use a 26-watt CFL for the breaker panel light fixture.

2. For the crane bay lights it asks to install a 2 gang weatherproof plate similar to the one in the wash bay. Since the wash bay was locked can you tell me if it is a standard weatherproof cover or more like the in use covers?

Response: Clarification - The wash bay was not locked. It was an administrative/supply office adjacent to the mechanical room that was locked and inaccessible at the site visit. The wash bay and crane bays are the structures outside the main building that only have roofs and no walls. We viewed two of the three structures [buildings] - 7950 and 7951 – at the site visit. It is these three structures [buildings] that require weatherproof covers over the new electronic light switches with integral off-delay timer per Section C (Scope of Work) paragraph 1.1.1.j.

3. On the 200 watt exterior light fixture it calls for a 42 watt compact fluorescent to be installed. The 42 watt was designed for base down operations only. Due to the heat that would be developed in the enclosed existing fixture that is on the buildings you will have premature bulb failure. Please advise as to weather you would like a different bulb or to go ahead and use the 42 watt as specified.

Response: Compact fluorescent lamps (CFL's) generally perform better in base up operation which keeps the lamp cooler. However, in addition to the CFL cut sheet provided with the bidder's question, GE also makes a universal burn 42W CFL to be used in either orientation. Additionally, GE's information indicates that CFL's can be used in enclosed fixtures, particularly exterior enclosed fixtures. They are not for use in enclosed recessed interior fixtures, i.e., can lights. The Government is not endorsing or promoting the use of products by any particular manufacturer. Products by any manufacturer which meet the specification and specific application will be acceptable.

Additional information – Design drawing for building 7940 has been corrected to indicate correct location of panel L3.

(End of Summary of Changes)